

Certificate



Certificate no.

CU 72143094 01

License Holder:

Bosch Rexroth AG
Bgm.-Dr.-Nebel Str. 2
D-97816 Lohr am Main
Germany

Manufacturing Plant:

-AS-30981388 005

Test report no.: USA-AS 30981388 006

Client Reference: Joachim Engel

Tested to:

UL 508:1999 R3.13
CAN/CSA C22.2 No. 142-M1987 (R2009)

Certified Product: Modular Safety Controller

License Fee - Units

Listing Category: Industrial Control Equipment

Model Designation:

SLC-3-CPU000300, SLC-3-CPU130302, SLC-3-MPL000301,
SLC-3-XTIO84302, SLC-3-XTDI80302, SLC-3-XTDS84302,
SLC-3-MOC000300, SLC-3-CPU320302, SLC-3-MPL100301

Rated Voltage: DC 30V

Rated Current: 4A


Protection Class: III

7

contd.

7

Licensed Test mark:



Date of Issue

(day/mo/yr)

08/12/2014

Certificate



Certificate no.

CU 72143094 02

License Holder:

Bosch Rexroth AG
Bgm.-Dr.-Nebel Str. 2
D-97816 Lohr am Main
Germany

Manufacturing Plant:

-AS-30981388 005

Test report no.: USA-AS 30981388 006

Client Reference: Joachim Engel

Tested to:

UL 508:1999 R3.13
CAN/CSA C22.2 No. 142-M1987 (R2009)


Certified Product: Modular Safety Controller

License Fee - Units

contd.

Special Remarks: To be installed according to the licensee's installation instructions. To be used in a pollution degree 2 environment only. Additionally evaluated to IEC 61508 Part 1-7:2010; EN 62061:2005+AC; EN ISO 13849-1:2008+AC; and EN 61326-3-1:2008.

Licensed Test mark:



Date of Issue

(day/mo/yr)

08/12/2014